

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0410:107 Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Hochiki America, 7051 Village Dr., Suite 100, Buena Park, CA 90621
Contact: Bob Misiuk (714) 670-3251

DESIGN: Models SLG-12, SLG-24, SLG-24FH, SLG-24F, SLK-12, SLK-24F, SLK-24FH, SLK-24FB, SLK-24FL, SLK-24FLB, SLK-835, SLK-835H, SLR-835, SLR-835W, SLR-835B-2, SLR-835B-4, SLR-835B-2W, SLR-835B-4W, SLR-24, SLR-24H, SLR-24V, *SLR-24VN, SLR-835H, SLR-835HW, SLR-835BH-2, SLR-835BH-2W, SLR-835BH-4, SLR-835BH-4W photoelectric type smoke detectors. Unit with suffix -H or -FH employs a supplemental heat sensor. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 VDC and 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with separately listed compatible fire alarm control units when used in conjunction with listee's listed bases (CSFM Listing No. 7300-0410:132). Models with supplemental heat sensor are not approved for use in lieu of required heat detectors.

NOTE: Formerly 7257-0410:107

*Rev. 2-14-2003 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 14, 2003**

Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**